



Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

PW/746

Gent

2019-04-03

Certification report 19/746

1. Description of the wall covering:

Product family	Type 06a: Wallcovering with textile
Total mass	370 g/m ²

2. Test results:

Classification according to EN13501-1:2007+A1 (2009)

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples. Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



CENTEXBEL • textile competence centre • www.centexbel.be
GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be
VAT • BE 0459.218.289 • **IBAN •** BE 44 2100 4729 6545 • **BIC •** GEBABEBB

addressee

Arte nv

our reference

PW/746

Gent

2019-04-03

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

B - s1, d0

field of application: glued (starch glue applied at the rate of 200 gr/m²) on end-use substrates having a density of 1350 kg/m³ or higher and classified A2-s1,d0 or A1.

Related commercial names to this product group

Paleo: Tribu, Copan

The obtained classification is based on the next test reports

AITEX: 2019AN0392

Validity of the certificate

05/03/2024

Petra Wittevrongel

Product Certifier

